### **Bussmann**®

# Panel-Mount Fuseholder

## 

## HPS Series



**Catalog Symbol:** HPS, HPS-EE, HPS-FF, HPS-JJ, and HPS-RR

#### Panel Mount


Agency Approvals: U.L. Recognized, Guide IZLT2, File E14853 CSA Certified: Class 6225-01, File 47235 Temperature Rating (RTI): 150°C


#### **Electrical Ratings**

Catalog		Volts	
Symbol	Amps	AC	Fuse Description
HPS	30	600	1½″ (38.1mm).
HPS-C*,**	15	250	1½" (38.1mm) clear knob.
HPS-L	5	600	BBS, <sup>1</sup> 3⁄ <sub>32</sub> " × 1¾" fuses.
HPS-EE	15	600	S.C. 0-15, <sup>13</sup> / <sub>32</sub> " × 15/16" fuses.
HPS-JJ	20	600	S.C. 20, <sup>13</sup> / <sub>32</sub> " × 1 <sup>13</sup> / <sub>32</sub> " fuses.
HPS-F-EE	15	600	Sleeve on body, leaded for $^{13}_{32}$ " $\times 15_{16}$ " fuses.
HPS-FF**	30	300	S.C. 25 & 30, <sup>13</sup> 32" × 1%" fuses.
HPS-RR**	30	600	KTK-R, LP-CC, FNQ-R Class CC fuses.
HPS-W*,**	30	600	$^{13}_{32}$ " × 1 $\frac{1}{2}$ " - Drip-proof knob.
* No U.L. Recognition			

\*\*No CSA Certification

#### **Dimensional Data**





#### **General Information:**

- Bayonet-type knob.
- For new designs see HPF series.
- Combination  $\frac{1}{4}$ " quick-connect/solder terminals. (Standard solder type terminals available.)
- The -EE, -JJ, -FF, and -RR holders are U.L. Listed for branch circuit protection.

C€ CE logo denotes compliance with European Union Low Voltage Directive (50-1000 Vac, 75-1500 Vdc). Refer to BIF document #8002 or contact Bussmann Application Engineering at 636-527-1270 for more information.

The only controlled copy of this BIF document is the electronic read-only version located on the Bussmann Network Drive. All other copies of this document are by definition uncontrolled. This bulletin is intended to clearly present comprehensive product data and provide technical information that will help the end user with design applications. Bussmann reserves the right, without notice, to change design or construction of any products and to discontinue or limit distribution of any products. Bussmann also reserves the right to change or update, without notice, any technical information contained in this bulletin. Once a product has been selected, it should be tested by the user in all possible applications.



Form No. HPS Series Page 1 of 1 BIF Doc #2113